

# Application Information Sheet

Page (s) **1** **1**

## Space Heating and Domestic Hot Water with Radiators

### Facts at a glance:

#### Heat pumps and radiators

Heat pumps can be effectively used with radiators, however they are certain considerations that need to be taken into account.

#### 45-50 degC flow temperature

Heat pumps with radiators require to increase their flow temperatures to 45-50°C which reduces the COP and hence efficiency.

#### Oversized hot water coils are required

The larger size the coil within the tank, the better the heat transfer area and hence the better the DHW performance will be. Due to the low flow temperatures generated by the heat pump the hot water tank must have an oversized coil to provide the correct heat transfer.

#### Simple Installation

Designed to simplify installation by removing the need for complicated control logic.

#### Off-Peak Tariffs

Due to the low water content of radiator systems and hence low thermal storage, off-peak tariffs such as Economy 10 can not be effectively used and a flat rate tariff might be more effective.

#### 50 degC DHW flow temperature

Domestic Hot Water flow temperatures achieved at approximately 50°C.

#### Principle of Operation

The Kensa compact heat pump is specifically designed to provide space heating at the highest efficiency possible with the simplest installation.

In space heating mode the system provides hot water into the radiator heating system at generally a flow temperature of 45—50°C. For heating in a well insulated building this will provide adequate heating into the building, however the sizing of the radiators will need to be checked. If the insulation of the building is below current regulations then this flow temperature might not be higher enough to provide sufficient heat into the building.

To avoid short cycling of the heat pump in space heating mode, it is advisable that approximately 25% of the radiators are used as bypass radiators, i.e. with no thermostatic controls on them. These bypass radiators should be in areas which do not require close temperature control such as hallways. If close temperature control is required in all zones a buffer vessel should be used.

The radiators should ideally be connected using a reverse return system as this will ensure even heat flow through the radiators without the use of balancing valves and the resulting increase in water pump energy.

Any microbore pipe will need to be removed as this does not allow the correct flow rate of hot water into the radiators and systems will also need to be power flushed before the system is commissioned.

Heat pumps will operate with radiators, however due to the higher flow temperatures (45-50C) the efficiency of such systems are lower than underfloor systems. COP's for radiator systems due to this higher flow temperature are generally around 3.

When the DHW time clock calls for production of DHW, the three-port valve diverts the flow from the heating distribution circuit into the indirect coil within the hot water cylinder. The temperature of the water from the heat pump is raised to approximately 50°C.

When the DHW production time period ends, the three port valve switches back to the underfloor distribution and the temperature drops back to its space heating design temperature. The heat pump then reverts to space heating mode or switches off if no zones are calling for heat.

The maximum DHW temperature that the heat pump can achieve will be approximately 50-55°C. If 65°C is required all year round, it is recommended that an immersion heater is linked to a second channel on the DHW timeclock and this is programmed to operate for a period immediately following the DHW production. This means that the majority of the heating load for the DHW is produced using the heat pump, as opposed to using only the direct immersion heater.

If 50°C water is acceptable, then it is recommended that the immersion heater is programmed to raise the temperature to 65°C once a week using the DHW timeclock.

Continued...

**Kensa Engineering Ltd**  
 Mount Wellington, Chacewater, Truro, Cornwall, TR4 8RJ  
 Tel: 01872 862140 Fax: 01872 862440  
 info@kensaengineering.com  
 www.kensaengineering.com

Copyright ©2009 Kensa Engineering Ltd


Certificate Number MCS1216  
Heat Pumps

Kensa Engineering Ltd  
 Truro, Cornwall  
 Company Registration  
 Number 3739805



# Application Information Sheet

## Space Heating and Domestic Hot Water with Radiators



### Abbreviations

- 3PDV - 3 port diverting valve
- DHW - Domestic Hot Water
- CW - Cold Water
- EXP - Expansion vessel
- GSHP - Ground source heat pump
- IH - Immersion heater
- IV - Isolation valve
- PRV - Pressure relief valve
- SM - Slinky manifold
- T - Thermostat
- UFM - Underfloor manifold
- WP - Water pump

**Please note:-** The above drawing is a schematic only and additional valves and fittings maybe required.

**Please note:-** Kensa supply is the ground source heat pump, DHW cylinder and slinky manifold. Kensa also supplies the horizontal ground arrays and antifreeze (not shown above).

**Please note:-** Running the GSHP to produce DHW with off-peak tariffs might result in the GSHP needing to operate during peak electricity periods for space heating with higher associated running costs.