

Fact Sheet

Ground Source Heat Pumps, Building Regulations and CO₂ Emissions.

Facts at a glance:

Building Regulations

Part L (Part J in Scotland) now states that the annual CO₂ emission rate or Dwelling Emission Rate (DER) of the completed building must not exceed a Target Emission Rate (TER)

SAP

Standard Assessment Procedure is the Government's standard methodology for assessing the energy consumption in new domestic dwellings.

SBEM

Simplified Building Energy Model (SBEM) is used to calculate the energy consumption for commercial projects.

CO₂ emissions

A ground source heat pump can reduce the CO₂ emissions by 29% over gas and 46% over oil.

Ground Source Heat Pumps


By using a ground source heat pump to provide a building's heating requirement the DER/BER of the building is reduced and hence the building is more likely to pass building regulations on the CO₂ emission requirements.

In 2006 the UK Building Regulations changed and one of the main requirements for meeting the energy efficiency criteria of the regulations (Part L, in England and Wales, Part J in Scotland) is now based on CO₂ emissions from the proposed building.

Part L now states that the annual CO₂ emission rate or Dwelling Emission Rate (DER) of the completed building must not exceed a Target Emission Rate (TER) set by reference to a notional building of the same size and shape.

The DER and TER are calculated according to the Standard Assessment Procedure (SAP) 2005 for domestic buildings and the Simplified Building Energy Model (SBEM) calculation for commercial projects. (For SBEM the DER is actually termed the Buildings Emission Rate or BER) SAP is the Government's standard methodology for assessing the energy consumption in new domestic dwellings. The latest version of SAP is SAP 2005. The SAP scale runs from 1 (poor) to 100 (excellent) and is based on estimated annual energy use for space heating, domestic hot water, ventilation and internal fixed lighting. A SAP of 100 now represents zero energy cost for these items. It can be above 100 for dwellings that are net exporters of energy.

A SAP Assessor, who are available nationwide, can provide a SAP report. SBEM uses a computer program developed by the Building Research Establishment (BRE) that provides an analysis of a commercial building's energy consumption. It is a recognised method to assist in demonstrating compliance with the Building Regulations Part L2A or L2B 2006, (England and Wales).



Kensa Engineering Ltd
 Mount Wellington, Chacewater, Truro, Cornwall, TR4 8RJ
 Tel: 01872 862140 Fax: 01872 862440
 info@kensaengineering.com
www.kensaengineering.com

Copyright ©2009 Kensa Engineering Ltd



Kensa Engineering Ltd
 Truro, Cornwall
 Company Registration
 Number 3739805



Fact Sheet

Ground Source Heat Pumps, Building Regulations and CO₂ Emissions.

An SBEM Energy rating is not a design of the heating, ventilation or lighting system, which may be required for more complex building types. SBEM can be provided by some SAP assessors, or a Building Services Engineering Company. Ground Source Heat Pumps can help dwellings achieve compliance with Building Regulations by reducing the DER/BER of buildings.

Ground Source Heat Pumps can help dwellings achieve compliance with Building Regulations by reducing the DER/BER of buildings.

The equation overleaf shows that by utilising the energy in the ground, a ground source heat pump can produce over twice the amount of energy for the same amount of initial energy input as a gas fired boiler. This means that the CO₂ emissions will be lower for a Ground source Heat Pump than other non-renewable fuels.

The following table is produced by the DEFRA in April 2008 and gives CO₂ emissions per kWh for different fuels.

Fuel	Kg CO ₂ /kWh
Electricity	0.54
Natural Gas	0.19
Coal	0.3
Oil	0.25
LPG	0.21

Although a Ground Source Heat pump uses electricity (which has the largest emission rate) as it can operate with a COP of 4, i.e. for every one kW of electrical energy used it produces 4 kW of thermal heat, the actual CO₂ emission rate for providing heat to a building is 0.135kg CO₂/kWh. This shows a CO₂ reduction of 29% over gas and 46% over oil.

By selecting a Ground Source Heat Pump to provide a building's heating requirement the DER/BER of the building is reduced and hence the building is more likely to pass building regulations on the CO₂ emission requirements.

For examples on how changing fuel sources, increasing insulation or adding solar panels to buildings, can alter a building's DER and TER, we suggest you visit www.playtheregs.com. The site is a simple on-line SAP assessment program written by the National Home Energy Rating (NHER) scheme and gives an indication on how changing a building's characteristics can alter its SAP rating and carbon emissions.